



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Administration
DIVISION OF PURCHASES
One Capitol Hill
Providence, RI 02908-5855

Tel: (401) 222-2317
Fax: (401) 222-6387
TDD: (401) 222-1228
Web Site: www.purchasing.ri.gov

9/27/2005

ADDENDUM #1

BID #B05573

BID TITLE: AIR DUCT CLEANING – D.O.C.

OPENING DATE AND TIME: 10/3/05 – 2:00 PM

Please note the following specifications to be included in your proposal.

- (1) Prevailing wage rate is not an issue for a cleaning service contract.
- (2) The kitchen exhaust hood information is as follows:
Duct Size 24" x 36"
Vertical to roof @ 65-ft. for each unit (2 in kitchen)
- (3) All duct cleaning to be done in accordance with National Air Duct Cleaning Association (NADCA). Standard ACR 2005 and related ASHRAE Standards.
- (4) Air quality testing to also include: Fungal Wipes, non-viable fungal air samples, volatile organic compounds (VOC's).

Acknowledge your receipt/understanding of these specifications on your bid.
Attach a Copy of this addendum to your bid when your bid is submitted.


John F. O'Hara, II
Senior Buyer

/db

I confirm receipt and understanding of Addendum #1 and have incorporated its provisions in my bid package.

COMPANY: _____

NAME (SIGNATURE) _____

TITLE: _____